Facility Name	 Date	
Contact Name		
Facility Address	 Phone ()	
City	Zip Code	
Wholesaler	 	

RETAIL FIREWORKS INSPECTIONS – 01F

(RETAIL STAND FIRE SAFETY FEATURES)

Kansas State Fire Marshal Retail Stand Fireworks Inspection Checklist - 01F

Item	Safety Feature	Met	Not Met	Comments	
01F-01	Storage-Fireworks Only				
01F-02	Storage/Handling Sign				
01F-03	No Smoking/Flames				
01F-04	Flammable Substances				
01F-05	Fire Extinguishers				
01F-06	Permitted Sale Dates				
01F-07	Sun/Glass Displays				
01F-08	Attendant On Duty				
01F-09	Sale/Handling Sign				
01F-10	Sale/No Smoking Sign				
01F-11	Permitted By Law				
01F-12	Storage/Gasoline/Liquids				
01F-13	Discharge/1000'-Hosp				
01F-14	Discharge/Vehicles				
01F-15	Discharge/Roadways				
01F-16	Discharge/50' Stand				
01F-17	Illegal Fireworks				
01F-18	Number of Exits				
01F-19	Emergency Lighting				
01F-20	Exit Signs				

- ♦ Complete POC and POC continuances giving detailed description and send to KSFMO in same manner as other inspection reports.
- ♦ Attach copy of this checklist to POC/POC continuances and send to KSFMO
- KIDS# category designation is 55

Retail Fireworks Checklist Item Descriptions

Item 01F-01 >> 22-6-2. Storage-Fireworks Only - Storage room is used for storage of fireworks only.

Item 01F-02 >> 22-6-2. Storage/Handling Sign - Posted sign over entrance.

Item 01F-03 >> 22-6-2. No Smoking Sign - Posted sign reads reading "FIREWORKS - NO SMOKING - KEEP OPEN FLAMES AWAY".

Item 01F-04 >> 22-6-3. Flammable Substances - Fireworks not sold/kept near paint, varnishes, turpentine, gasoline or other flammable substances.

Item 01F-05 >> 22-6-4. Fire Extinguishers - Two approved (2A10BC minimum) fire extinguishers provided and kept in close proximity. Two dipping buckets and barrel of water may be provided in lieu of extinguisher if stand is small and temporarily erected. A loaded water hose with nozzle end within 15 feet of fireworks stand may be provided in lieu of extinguisher if stand is small and temporarily erected.

Item 01F-06 >> 22-6-5. Permitted Sale Dates - Sale of fireworks not permitted before June 27^{th} and not after July 5^{th}

Item 01F-07 >> 22-6-6. Sun/Glass Displays - If displayed behind glass in sunny conditions, the merchandise must be original packaging.

Item 01F-08 >> 22-6-6. Attendant On Duty - Attendant must be on duty at all times unless fireworks are displayed in showcases out of the reach of the public.

Item 01F-09 >> 22-6-6. Sale Sign - Posted sign that reads "FIREWORKS FOR SALE"

Item 01F-10 >> 22-6-6. No Smoking Sign - Posted sign that reads "NO SMOKING ALLOWED"

Item 01F-11 >> 22-6-7. Permitted By Law - Fireworks must be Class C (consumer) fireworks. Class B (display) fireworks are not permitted. Bottlerockets and Skyrockets are not permitted. See KSA 31-155 for further information and description.

Item 01F-12 >> 22-6-8. Storage/Gasoline/Liquids - Must be at least 50 feet from gasoline pump, filling station, bulk gas station or any building where gasoline or volatile liquids are stored in excess of one gallon.

Item 01F-13 >> 22-6-9. Discharge/1000 Feet From Hospital - Fireworks not permitted to be discharged within 1000 feet from hospital, sanitarium, or infirmary.

Item 01F-14 >> 22-6-9. Discharge From/Under Vehicles - Fireworks are not permitted to be discharged from, into, under, or on any vehicle whether it is moving or standing.

Item 01F-15 >> 22-6-9 Discharge/Roadway - Fireworks are not permitted to be discharged on a public roadway or the right-of-way adjoining a public roadway.

Item 01F-16 >> 22-6-9 Discharge/50 Feet From Retail Stand and Storage Area - Fireworks are not permitted to be discharged within 50 feet of any retail stand or facility where fireworks are stored.

Item 01F-17 >> 22-6-12 Illegal Fireworks - Refer to checklist item 01F-11, if not met notify KSFMO immediately, confiscate fireworks, and complete seized fireworks receipt. Give copy of Kansas Statutes and Regulations sheet to retail stand representative.

Item 01F-18 >> Life Safety Code 25-2.4 Number of Exits - At least two separate and remote exits shall be provided for every building or tent where the public can occupy the facility.

Item 01F-19 > Life Safety Code 25-2.9 Emergency Lighting - Emergency lighting shall be provided in facilities that have 3,000 sq. ft. or more of gross floor area.

Item 01F-20 > Life Safety Code 25-2.10 Exit Signs - The means of egress shall be marked with approved signs readily visible from any direction. *Exception: Where an exit is immediately apparent from all portions of the sales area, the exit marking is not required.*